



THE MUNICIPALITY OF OLIVER PAIPOONGE
3250 Hwy 130, Rosslyn ON P7K 0B1
Telephone: (807) 935-2613
Fax: (807) 935-2161

April 25, 2019

ADDENDUM #2

Tender 05-2019

To supply and install one (1) new heating & cooling rooftop air unit with economizer at the municipal office building (to replace existing two units serving the main floor area).

For the Corporation of the Municipality of Oliver Paipoonge
~ Public Works Department ~

The Municipality has decided to amend the tender from supplying a roof top heating and cooling unit for the Municipal office to supplying two (2) new gas high efficiency combination furnace/air conditioning units.

Clarification/Answers to Questions

1. **Q.** The current duct outside is not insulated and cladded, are you looking to have this included in the tender?
 A. Yes, please include in the Tender.
2. **Q.** Are the units to sit on stands or on the slab?
 A. Proponents Choice
3. **Q.** On the site visit we had talked about downsizing slightly to 10 ton units is this still ok?
 A. Yes, as long as the units meet the requirements.
4. **Q.** Are these going to be condensing Hvac units or just regular units like you currently have.
 A. Regular Units like we currently have.

This addendum forms and becomes part of Tender 05-2019 and shall be acknowledged in Acknowledgment of Addendum of the tender document.

Chris Bowles
Director of Operations
Tel: (807) 935-2613 ext. 222
Fax: (807) 935-2161
Email: chris.bowles@oliverpaipoonge