



**THE MUNICIPALITY OF OLIVER PAIPOONGE**

3250 Highway 130  
Rosslyn, ON, P7K 0B1  
Telephone: (807) 935-2613  
Fax: (807) 935-2161

April 25, 2019

**ADDENDUM #1**

**Tender 08-2019**

---

**Reconstruction for John St. Road, Vibert Road, and  
Road Construction For Wrigley Drive and Harstone Drive**

---

For The Corporation of the Municipality of Oliver Paipoonge

**Clarification/Answers to Questions**

1. **Q.** I see in the tender documents (5.1) that it states granular material for culverts will be paid under the applicable gravel item. I do not see Granular B items in all the sections. Will we just include the granular material in the cost of the culverts?  
**A.** Contractor to use material provide at Municipal Pit free of charge. Contractor is responsible for loading, hauling and placement of the material
2. **Q.** I am trying to verify the 6290m<sup>2</sup> of scarify item. The tender notes it being between Fire entrance 10720 and Maki Road which is about 2.4 km. But that does not make sense with the given qty. Is it possible we are not scarifying the entire length?  
**A.** Yes. Scarification will occur between the West limit of the frost heave and the railway crossing
3. **Q.** For location 3. Are the 2 -1200m culverts that are being replaced located on Ridler road?  
**A.** No, Vibert Road south of tracks.
4. **Q.** For location 4 Does the ditch construction involve removing the large trees off site? Does shoulder correction -1m mean the contractor is removing 1m of shoulder?  
**A.** No tree removal required. For the shoulder, blade the material off at appoint 4.0m from the center line and beyond at 8% prior to granular "M" placement
5. **Q.** Are the road excavations large enough to use a grade roller for proof rolling of bottom elevation or does it have to be a plate packer?  
**A.** Grader Roller.
6. **Q.** For location 3. There is no gravel listed. Is the Gravel being reused or is the township supplying Gravel, or is the contractor supplying gravel for the Culvert changes?  
**A.** Please refer to question number 1 response.

This addendum forms and becomes part of Tender 08-2019 and shall be acknowledged in Section 2.4 on page 12 of the Tender Document.

Chris Bowles  
Director of Operations  
Tel: (807) 935-2613 ext. 222  
Email: [chris.bowles@oliverpaipoonge](mailto:chris.bowles@oliverpaipoonge)